

ORDINANCE NO. 7

Repealed by Ord. #10

A GENERAL REGULATION ORDINANCE OF THE MIDWAY CITY SANITARY DISTRICT, OF ORANGE COUNTY, CALIFORNIA, AMENDING SECTION 9, AS AMENDED, OF GENERAL REGULATION ORDINANCE NO. 3 OF SAID DISTRICT.

THE GOVERNING BOARD OF THE MIDWAY CITY SANITARY DISTRICT, of Orange County, California, does ordain as follows:

Section 1: That Section 9, as amended, of General Regulation Ordinance No. 3 of the Midway City Sanitary District be and the same hereby is further amended so as to read as follows:

"SECTION 9: Connecting sewers and house sewers shall be constructed of vitrified clay, tile, cast iron or such other materials as may be approved by the Governing Board of the District. All vitrified clay pipe and fittings shall conform in every respect with the requirements of the specifications for glazed vitrified clay pipe of the Clay Products Institute of California, Southern Division, said specifications being made a part of this ordinance. Cast iron pipe and fittings shall be of the grade known as 'standard' soil pipe.

"LAYING OF PIPE

"Grade: Grade of all sewers covered by this ordinance shall not be less than one-quarter inch to the foot towards the outlet and all sections must be laid in perfect line on bottom and sides. Cross cuts deep enough to receive the socket of the pipe shall be cut in the bottom of the trench so that the pipe will not rest on the socket or collars, but have a bearing the full length of the pipe.

"Size of Pipe: Connecting Sewers may be constructed of four inch pipe, provided the number of fixtures served is not over thirty-six (36). If the number of fixtures exceeds thirty-six (36), the size of the pipe of the connecting sewer shall be six (6) inches or larger.

"Alignment: All changes in direction shall be made by the use of wyes and one-eighth bends, and any change from one size pipe to another size shall be made by use of a reducer. Where four inch clay pipe is to

be connected to a section of four inch cast iron pipe, connection shall be made so that the flow line of each pipe shall be on the same line.

"Openings: All wye and tee openings in sewers, which are not used for connections, shall be closed by the use of caps securely cemented.

"Joints and Connections: Joints in vitrified clay pipe shall be made of mortar composed of one part of Portland cement and two parts of clean sharp sand, thoroughly mixed while dry, and enough water then added to give the proper consistency. Joints must be pointed carefully on the outside and the pipe left clean and smooth on the inside by drawing through it a swab or scraper."

Section 2: That all motions, resolutions and ordinances, and parts thereof, in conflict herewith be, and the same hereby are, repealed to the extent of such conflict and no further.

Section 3: The Secretary of the Governing Board of this District shall certify to the passage of this ordinance and shall cause the same to be published once in the WESTMINSTER HERALD, a newspaper of general circulation printed, published and circulated in the Midway City Sanitary District, of Orange County, California, and this ordinance shall be in full force and effect at the expiration of one week from and after the date of its final passage.

ADOPTED, SIGNED AND APPROVED this 3rd day of October, 1957.

ATTEST:

Fred W. Gray
Secretary

J. R. Durham
President *Pro Tem*

